



MERCURY DISPLACEMENT INDUSTRIES, INC.

Post Office Box 710 - U.S. 12 East - Edwardsburg, Michigan 49112-0710

Phone (269) 663-8574 - Fax (269) 663-2924

(800) 634-4077

SS30DE-1




E 62767
Industrial Control
Equipment




- Zero Cross Switching - Single Phase
- Rated Voltage: 42 - 600 V +10% -15% on max.
- **Line & Load accepts: 10-18 AWG**
- Control Voltage: 4-32 VDC
- Rated Current: 30 AAC @ 40°C (Refer to Chart)
8 AAC AC-53a @ 25°C
- Blocking Voltage: 1200 Vp
- Min. operational current: 250 mAAC
- I²t (10ms) 1800 A²s

Terminal Layout and Dimensions



Derating vs. Spacing Curves @ AC-51 rating



Contactors - Relays - Switches

<http://www.mdious.com>